



York Risk Control
 4021-A Ambassador Caffery Pkwy, Ste. 100
 Lafayette, LA 70503
 (877) 586-3272 * FAX (337) 216-0453

Loss Control Survey Recommendations

Insured Name:
 Contact:
 Policy #:
 WR #:

Underwriter:
 Program Name:
 Survey Date: 10/10/2019
 ID #:

Letter Date: October 15, 2019

Please respond in writing within 14 days of the date of this letter as to the status of the recommendations submitted. We appreciate your attention to this matter. Failure to respond may jeopardize your insurance coverage. Thank you again for your cooperation.

Please write your response to each of the recommendations in the space provided below. Your response can be mailed, faxed, emailed or entered through the hyperlink below.

York Risk Control
 4021-A Ambassador Caffery Parkway, Suite 100
 Lafayette, LA 70503
 Fax (337) 216-0453
 Email: RecResponse@yorkrsg.com

Enter Response On-Line URL: <https://www.iauditexpert.com/static/responses.htm?ExtKey=oikadbkkOiljihGC>

Recommendations For Location:

Essential Recommendations:

2019-10-01: Portable Fire Extinguishers

To reduce property damage as a result of a fire, we recommend properly locating ABC rated fire extinguishers throughout the building(s). They should be placed in visible areas and/or near likely sources of ignition to enable occupants of the building to better respond in the event of a fire in the building. For additional information about the size, locations, and number of fire extinguishers appropriate for your facility, contact your local fire department or a fire protection consultant.



These are private residents and I have sent out reminder e-mail to entire n'hd to make sure they check

2019-10-02: Cut back tree limbs that overhang. Falling limbs can damage the roof surface.



Attached is our recent quote for tree trimming that will be scheduled this fall. I will follow up with pictures.

Signature: _____

Date: 10-16-19

Print Name: _____

Title: Prop. Mgr.

"Our survey of your operations is for underwriting purposes and to assist you in your loss control activities. However, no responsibility is assumed for the discovery and elimination of hazards which could possibly cause accidents or damage at any facility that is inspected. Compliance with any submitted recommendations in no way guarantees the fulfillment of your obligations as may be required by any local, state or federal laws."